

May 22, 2026

Lisa,

The Fire Department offers the following responses to the item: Middle Road – Brush and Hammer Builders Inc.


- Any driveway, bridge, culvert, or other structural component intended to provide required fire department access shall be designed to support imposed loads from fire apparatus with a gross vehicle weight of not less than 80,000 pounds.
- Due to the length of the proposed driveway, a fire apparatus turnaround is required.

If you have any questions or concerns, feel free to contact me.

Nicholas J. Pelletier

Assistant Fire Chief
Falmouth Fire-EMS
8 Bucknam Road
Falmouth, ME 04105
(207)781-2610 ext. 5251
Fax (207)699-5268

Email: npelletier@falmouthme.org



Under Maine's Freedom of Access ("Right to Know") law, all e-mail and e-mail attachments received or prepared for use in matters concerning Town business or containing information relating to Town business are likely to be regarded as public records which may be inspected by any person upon request, unless otherwise made confidential by law