

May 22, 2026

Lisa,

The Fire Department offers the following responses to the item: 78 Leighton Road – Falmouth Dentistry


- No new comments
- Reiteration of previous comments:
- Construction will require a State Fire Marshall Permit
 - Knox box required
 - Alarm System required
 - All emergency exits and paths of egress lead to maintained walkways that lead to a public way.

If you have any questions or concerns, feel free to contact me.

Nicholas J. Pelletier

Assistant Fire Chief
Falmouth Fire-EMS
8 Bucknam Road
Falmouth, ME 04105
(207)781-2610 ext. 5251
Fax (207)699-5268

Email: npelletier@falmouthme.org



Under Maine's Freedom of Access ("Right to Know") law, all e-mail and e-mail attachments received or prepared for use in matters concerning Town business or containing information relating to Town business are likely to be regarded as public records which may be inspected by any person upon request, unless otherwise made confidential by law